

Printed on: 11 Aug 2011

Registration No.	96
Title	Sumitube W3NH Heat Shrink Tubing
Status	Authorised For Use
Supersedes ProductID	N/A
Superseded By ProductID	N/A
Date Authorised for Use	11 Aug 2011
Primary Use	Heat shrink tubing for the on-site construction of cable joints and the repair of damaged cable jackets, in electrical installations in stations and tunnels.
Additional Info/KeyWords	Sumitube W3NH has an inner wall of hot melt adhesive. A high shrink ratio eases installation on transitions with large diameter gaps. It is compliant with the requirements for cable joints of London Underground Manual of Good Practice, G-085 A3. Therefore, the total amount of material that can be used in sub-surface locations is limited to 450g in tunnels or 1500g in station environment. See Entry No. 98 for composite Joint Installation details. Sumitube NH without adhesive is Entry No. 97. Manufacturer: Sumitomo Electric Schrumpf-Produkte GmbH, Germany. UK Supplier: Sumitomo Electric, Shrink Products, 3 Sutton Park, Blunsdon, Swindon, SN26 7BA. Tel: 01452 812511.
Classification Hierarchy	Electrical
Manufactured By	Sumitomo Electric Shrink Products

Requirements

ReqID	Requirement	Status	Trial
No records to display.			

Conditions

Description	Linked To ReqID
Install according to the manufacturer's instructions. See Entry No. 98 for further details.	

Evidence

EvidenceText	EvidenceType	FileName	Linked To ReqID
Technical data sheet: Sumitube W3NH	User Guide	tds W3NH 051105-01.pdf	
Certificate of Conformity	Other	C of C_W3NH.pdf	
ISO 9001 Certification	Other	SESP ISO 9001 (E) 1-2.jpg	
Compliance with RoHs/EU Directives	Other	sumitomo-sumitube_rohs_conformity_newsletter_feb_2006.pdf	

Refer to Web site www.lu-apr.co.uk to check current status, download attachments and for details of other products.

MAYOR OF LONDON